


33485 Vinewood in
 Lot 24, Block 2
 Quetta Woods
 Seward, AK

VINEWOOD LANE



North

From: "Wall, Bruce" <bwall@kpb.us>
Date: April 29, 2016 at 3:42:28 PM AKDT
To: "'lizdemoss26@yahoo.com'" <lizdemoss26@yahoo.com>
Cc: "Ring, Katie" <kring@kpb.us>
Subject: Marijuana Establishment Application (License 10122)

Elizabeth,

In reviewing the site plan that you have submitted, it is not clear what the width of the driveway is where it accesses Vinewood Lane. KPB 7.30.020C requires a 28-foot width at the access point. Please provide an updated site plan that clarifies this issue.

Thanks,

Bruce Wall, AICP
Planner
Kenai Peninsula Borough
907-714-2206